



**Dŵr Cymru**  
**Welsh Water**

Developer Services  
PO Box 3146  
Cardiff  
CF30 0EH

Tel: +44 (0)800 917 2652  
Fax: +44 (0)2920 740472  
E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu  
Blwch Post 3146  
Caerdydd  
CF30 0EH

Ffôn: +44 (0)800 917 2652  
Ffacs: +44 (0)2920 740472  
E.bost: developer.services@dwrcymru.com

PFM  
Recd.

Herefordshire Council  
PO Box 230  
Blueschool House  
Blueschool Street  
Hereford  
HR1 2ZB

**Date: 05/06/2014**  
**Our Ref: PLA0006020**  
**Your Ref: 140757/O**

Dear Sir,

**Grid Ref: SO5674541017 356745 241017**

**Site: Land East of Church House & West of A438, Bartestree**

**Development: Residential development of up to 51 new dwellings of which up to 18 will be affordable.**

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

### SEWERAGE

We would request that if you are minded to grant Planning Consent for the above development that the Conditions and Advisory Notes listed below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

Foul water and surface water discharges shall be drained separately from the site.

Reason: To protect the integrity of the public sewerage system.

No surface water shall be allowed to connect, either directly or indirectly, to the public sewerage system unless otherwise approved in writing by the Local Planning Authority.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no detriment to the environment.

Land drainage run-off shall not be permitted to discharge, either directly or indirectly, into the public sewerage system.

Reason: To prevent hydraulic overload of the public sewerage system and pollution of the environment.

**glas**  
Glas Cymru Cyfyngedig


Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treheris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nglymru rhif 2366777. Swyddfa gofrestradig: Heol Pentwyn  
Nelson, Treheris, Morgannwg Ganol CF46 6LY.



The proposed development site is crossed by a public sewer with the approximate position being marked on the attached Statutory Public Sewer Record. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times. No part of the building will be permitted within 3 metres either side of the centreline of the public sewer.

**Reason:** To protect the integrity of the public sewer and avoid damage thereto.

No development shall commence until the developer has prepared a scheme for the comprehensive and integrated drainage of the site showing how foul water, surface water and land drainage will be dealt with and this has been approved by the Local Planning Authority.

**Reason:** To ensure that effective drainage facilities are provided for the proposed development, and that no adverse impact occurs to the environment or the existing public sewerage system.

### **Advisory Notes**

If a connection is required to the public sewerage system, the developer is advised to contact Dwr Cymru Welsh Water's Developer Services on 0800 917 2652.

Some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal we request the applicant contacts our Operations Contact Centre on 0800 085 3968 to establish the location and status of the sewer. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

The Welsh Government have introduced new legislation that will make it mandatory for all developers who wish to communicate with the public sewerage system to obtain an adoption agreement for their sewerage with Dwr Cymru Welsh Water (DCWW). The Welsh Ministers Standards for the construction of sewerage apparatus and an agreement under Section 104 of the Water Industry Act (WIA) 1991 will need to be completed in advance of any authorisation to communicate with the public sewerage system under Section 106 WIA 1991 being granted by DCWW.

Welsh Government introduced the Welsh Ministers Standards on the 1st October 2012 and we would welcome your support in informing applicants who wish to communicate with the public sewerage system to engage with us at the earliest opportunity. Further information on the Welsh Ministers Standards is available for viewing on our Developer Services Section of our website - [www.dwrcymru.com](http://www.dwrcymru.com)

Further information on the Welsh Ministers Standards can be found on the Welsh Government website - [www.wales.gov.uk](http://www.wales.gov.uk)

### **SEWERAGE TREATMENT**



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dwr Cymru yn eiddo Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dwr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dwr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

No problems are envisaged with the Waste Water Treatment Works for the treatment of domestic discharges from this site.

### **WATER SUPPLY**


No problems are envisaged with the provision of clean water supply to serve the development site.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at [developer.services@dwrcymru.com](mailto:developer.services@dwrcymru.com)

Please quote our reference number in all communications and correspondence.

Yours faithfully,



















**Sonny Robinson**  
**Development Control Officer**  
**Developer Services**



PLA0006020



**LEGEND(Representative of most common features)**

- |   |  |  |   |   |  |   |   |
|---|--|--|---|---|--|---|---|
| <br>Relative frequency | <br>Pie chart | <br>Bar chart | <br>Scatter plot | <br>Line graph | <br>Histogram | <br>Box plot | <br>Dot plot |
| <br>Relative frequency | <br>Pie chart | <br>Bar chart | <br>Scatter plot | <br>Line graph | <br>Histogram | <br>Box plot | <br>Dot plot |

**Notes:**

Medical survey respondents also have been taken to correctly record the pipe material of DCHME emitters. There is a possibility that in some cases pipe material (other than Austenitic Corrosion or Polyethylene) may be found to be suitable for use in the system (AC or Polyethylene). It is therefore advisable that the possible presence of AC or PE pipes be investigated and considered as part of any risk assessment to ensure safety.

The Omani CV gave the information as to the position of the underground aquifer by way of plotted guidance only on the basis of understanding that it is based on the best information available and no warranty as to its correctness is offered upon it in the event of alterations or other events made in the vicinity of the Company's apparatus and any cause of locating the apparatus without carrying out any connections was entirely on you. It must be understood that the turning of the column is entirely optional. The information is provided as the New Republic of Oman, 1991 and of the Company's right to be compensated for the use of the information.

Services are provided but their production should be anticipated.

**EXACT LOCATIONS OF ALL APPARATUS  
TO BE DETERMINED ON SITE.**

Reproduced by permission of Ordnance Survey on behalf of  
HMSO. © Crown copyright and database right 2002.  
All rights reserved.  
Ordnance Survey License number 10001834.

Map Ref: 356579,241025

Map scale: 1:1,250

Printed by: DP

Printed on: 22/04/2014

