

Planning application comment was submitted on the **07 August 2023 12:09 PM**

The following is a comment on application **P231889/O** by **Stephen Fellows**

**Nature of feedback: Submitting a general comment**

---

**Comment:** Fire Service Vehicle access must comply with the requirements of ADB 2019 Vol. 1 B5, section 13 & Table 13.1

In particular – there should be Fire Service vehicle access for a Fire Appliance to within 45 metres of all points inside dwelling houses/Flats.

Access road and hardstandings to be in accordance with ADB 2019 Vol. 1 Table 13.1

Dead-end access routes longer than 20m require turning facilities,

Water for firefighting purposes should be provided in accordance with: ‘ National guidance document on the provision of water for fire - fighting’ and BS 9990

**Attachment:**

---

Their contact details are as follows:

**First name:** Stephen

**Last name:** Fellows

**Email:** sfellows@hwfire.org.uk

**Postcode:** WR3 8SP

**Address:** Hindlip Hall

Worcester

---

**Infrastructure from section 106 to consider:** No Comment

---

Link ID: [https://www.herefordshire.gov.uk/info/200142/planning\\_services/planning\\_application\\_search/details?id=231889](https://www.herefordshire.gov.uk/info/200142/planning_services/planning_application_search/details?id=231889)

Form reference: FS-Case-537448674