

From: Harrison, Lauren <Lauren.Harrison@balfourbeatty.com>
Sent: 17 August 2022 13:11
To: Bailey, Josh <Joshua.Bailey@herefordshire.gov.uk>
Subject: 222088 - Old Leys, Walford

This message originated from outside of Herefordshire Council or Hoople. Please do not click links or open attachments unless you recognise the sender and know the content is safe.

Hi Josh,

We have been reviewing the addition information for this site. We note that the 'worst case' result from the percolation testing has been provided but it is not clear to what depth the trial pit was excavated. Please could this be clarified and the results from the other two trial pits also be submitted. The drainage field has been sized using a potential population of 4 however this should be 5 for a 3-bedroom dwelling. The drainage field sizing should be amended accordingly.

Despite previous requests, no further surface water drainage information has been provided. Infiltration testing has also not been undertaken. We request further clarification of the surface water drainage proposals.

Upon this information being provided, we will look to provide a formal consultation response.

Kind regards,
Lauren

Lauren Harrison

Graduate Flood Risk Consultant | Balfour Beatty | Services | Living Places | Herefordshire Public Realm

(Seconded to BBLP from Waterman Aspen)

M: 07972 491164 | E: Lauren.Harrison@balfourbeatty.com

Balfour Beatty Living Places | Unit 3, Thorn Business Park | Rotherwas | Hereford | HR2 6JT

Download the : [Herefordshire SuDS Handbook](#) and the [Strategic Flood Risk Assessment \(Level 1\)](#)

Watch our latest Expert video to learn how our Automated Cone Laying Machines reduce the risks associated with cone laying activities.

This email may contain information which is confidential and is intended only for use of the recipient/s named above. If you are not an intended recipient, you are hereby notified that any copying, distribution, disclosure, reliance upon or other use of the contents of this email is strictly prohibited. If you have received this email in error, please notify the sender and destroy it. 'Think before you print - please do not print this email unless you really need to' Balfour Beatty plc is registered in England as a public limited company; Registered No: 395826; Registered Office: 5 Churchill Place, Canary Wharf, London E14 5HU Warning: Although the company has taken reasonable precautions to ensure no viruses or other malware are present in this email, the

company cannot accept responsibility for any loss or damage arising from the use of this email or attachments.