

PFD NO COj

MEMORANDUM

_					
To	:	Mr P Mullineux.	Development Control	l. Blueschool House -	H31

From : Dave Davies, Area Engineer, Transport Planning, Plough Lane - H37

Date : '	14 May 2012				
Application No	o: N 120932 /F				
Description :	Erection of 50kw solar photvoltaic array in part of field (retrospective)				
Site :	Strathmore Barn field, Lyonshall, Kington, Herefordshire HR5 3HS				
Grid Ref :	33392564				
COMMENTS:	2. Has no objection to the grant of permission SITE VISITED:				
ADDITIONAL COMMENTS:	Shielded by hedge, so reflections should not affect passing drivers, provided the hedge remain high. Can we condition retention of a high hedge to protect drivers from reflections of the setting sun, for instance?				
S106 COMMENTS:					
	S106 sum requested: £0.00				
CONDITIONS:	???? HIGHWAY NOTES:				

COMMENTS BY:

Dave Davies, Area Engineer

DATE COMMENT MADE

14 May 2012

HEREFORDSHIRE COUNCIL PLANNING SERVICES DEVELOPMENT CONTROL

16 MAY 2012

То:	
Ankidi nengganasana	