

Developer Services PO Box 3146 Cardiff CF30 0EH

Tel: +44 (0)800 917 2652 Fax: +44 (0)2920 740472

E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu Blwch Post 3146 Caerdydd CF30 0EH

Ffôn: +44 (0)800 917 2652 Ffacs: +44 (0)2920 740472

E.bost: developer.services@dwrcymru.com

Herefordshire Council PO Box 230 Blueschool House Blueschool Street Hereford HR1 2ZB

> Date: 22/05/2015 Our Ref: PLA0012033 Your Ref: 151317

Dear Sir,

Grid Ref: SO5015039766 350150 239766

Site: 28 Breinton Road, Hereford

Development: Proposed change of use to HMO (8 persons)

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We would request that if you are minded to grant Planning Consent for the above development that the <u>Conditions</u> provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

SEWERAGE

Conditions

No net increase of surface water shall be allowed to connect (either directly or indirectly) to the public sewerage system.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no detriment to the environment.

WATER SUPPLY

Dwr Cymru Welsh Water has no objection to the proposed development.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.



If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Sonny Robinson
Development Control Officer
Developer Services

