

From: Brace, Carl
Sent: 20 February 2020 11:05
To: info@condylofthouse.co.uk
Subject: 200195 - Martins Way

FAO Greg Phillips

Dear Greg,

We have reviewed the CEMP which is acceptable apart from the hours of delivery to site and construction. The applicant is proposing these from 07:00 to 20:00. This would be outside what we through Environmental Health, normally restrict ie 08:00 to 18:00. Given the proximity of neighbours the times proposed are not acceptable.

If the enclosed comments can be addressed by return I can discharge the condition,

Regards

Herefordshire.gov.uk

Carl Brace BSc (Hons), MA, MRTPI
Economy and Place Directorate
Principal Planning Officer
Development Management
Plough Lane Offices Hereford HR4 0LE
Tel | 01432 261947

Council's Homepage www.herefordshire.gov.uk
Planning Homepage <https://www.herefordshire.gov.uk/planning/>
Search Planning Applications <https://www.herefordshire.gov.uk/planning-and-building-control/development-control/search-and-comment-on-planning-applications/>