

	Hoople Ltd. Plough Lane, Hereford. Herefordshire. HR4 0LE. Tel: 01432 383678 – Email: RLIDB@hoopletd.co.uk	
--	---	--

To Case Officer	Mr Simon Withers simon.wiithers@herefordshire.gov.uk
------------------------	--

Our Ref:	PR2018-006
Date:	23rd August 2018

SITE:	Land adjoining Fairleigh Shelwick Green. Hereford HR13AW.
APPLICATION TYPE:	Reserved Matters
DESCRIPTION:	Reserved matters following outline approval 162436/O (two bedroom cottage).
APPLICATION NO:	P182641/RM
GRID REFERENCE:	OS 352835 - 243002
APPLICANT:	Mr Raymond Wilson

With reference to the above application dated 23rd August 2018. The Board must advise that this site is located within to its rateable area and has the potential to have direct effect on the Board's operational interests and watercourses under the Board's control.

I would like to inform you of the Board's standard requirements in respect of surface water disposal and ask that they be taken into consideration when the application is assessed.

Requirements	
1	Rates for storm water runoff discharged from the site to replicate or achieve a reduction from the 'greenfield' response of the site over a range of storm probabilities, accompanied by the <i>required On-site Storage</i> designed for the 1 in 100 year storm event.
2	For the range of annual flow rate probabilities, up to and including the 1% annual probability (1 in 100 year storm event) the developed rate of run-off <i>discharged from the site into an ordinary watercourse shall be no greater than the undeveloped rate of run-off for the same event.</i>
3	The potential effect of future climate change shall be taken into account by increasing the rainfall depth by 10% for computing storage volumes.
4	All in compliance with The Institute of Hydrology Report 124 (IoH 124) - <i>Flood estimation for small catchments (1994)</i>
5	All to the satisfaction of the Engineer to the Board
6	No additional surface water run-off to adjacent watercourse or any outfall structure is permitted without written Land Drainage Consent , which would have to be obtained from the Board under the terms of <i>the Land Drainage Act 1991</i> and the <i>Flood and Water Management Act 2010</i> .

I would also draw your attention to:

- *The area of River Lugg Internal Drainage Board is a Natural Flood Plain and whilst every effort will continue to be made to guard against and to alleviate flooding, no guarantee can be given against the worst effects of abnormal weather and river conditions.*
- *Compliance with the recommendations in the following Report: "Technical Guidance to the National Planning Policy Framework 2012".*
- *That both current and future developers/owners should be made aware of the risks associated within the area being considered.*

River Lugg
Internal Drainage Board

Hoople Ltd. Plough Lane, Hereford.
Herefordshire. HR4 0LE.
[Tel: 01432 383678](tel:01432383678) – Email:
RLIDB@hoopleltd.co.uk



Yours Sincerely

The River Lugg Internal Drainage Board
RLIDB@hoopleltd.co.uk