

**From:** Paul Smith <paulsmithplanning@outlook.com>  
**Sent:** 03 August 2021 10:05  
**To:** Gosset, David <david.gosset@herefordshire.gov.uk>  
**Cc:** Tim Fycun [REDACTED]  
**Subject:** RE: Drawing - Land Adjacent Amarant House, Harewood End.

This message originated from outside of Herefordshire Council or Hoople. Please do not click links or open attachments unless you recognise the sender and know the content is safe.

Dear Mr. Gosset,

My Drainage Consultant confirms that a safety factor of 2 was used for the soakaways.

Yours sincerely,

Paul Smith MRTPI

**From:** Gosset, David <david.gosset@herefordshire.gov.uk>  
**Sent:** 03 August 2021 08:45  
**To:** Paul Smith <paulsmithplanning@outlook.com>  
**Cc:** Tim Fycun [REDACTED]  
**Subject:** RE: Drawing - Land Adjacent Amarant House, Harewood End.

Dear Mr Smith,

Just to be sure, is that to say that a safety factor of 2 was used for the soakaways? That's certainly the impression but the content of BS6297 is not my speciality.

Thanks,  
David.

**Herefordshire.gov.uk**

**David Gosset**  
**Senior Planning Officer**

**Economy and Place Directorate**

E: [david.gosset@herefordshire.gov.uk](mailto:david.gosset@herefordshire.gov.uk)

Main Council Switchboard:  
01432 260000  
General Planning Enquiries:  
[planning\\_enquiries@herefordshire.gov.uk](mailto:planning_enquiries@herefordshire.gov.uk)





Please consider the environment - Do you really need to print this E-Mail?

Any opinion expressed in this e-mail or any attached files are those of the individual and not necessarily those of Herefordshire Council. This e-mail and any files transmitted with it are confidential and intended solely for the use of the addressee. This communication may contain material protected by law from being passed on. If you are not the intended recipient and have received this e-mail in error, you are advised that any use, dissemination, forwarding, printing or copying of this e-mail is strictly prohibited. If you have received this e-mail in error, please contact the sender immediately and destroy all copies of it.

**From:** Paul Smith <[paulsmithplanning@outlook.com](mailto:paulsmithplanning@outlook.com)>  
**Sent:** 02 August 2021 15:33  
**To:** Gosset, David <[david.gosset@herefordshire.gov.uk](mailto:david.gosset@herefordshire.gov.uk)>  
**Cc:** Tim Fycun [REDACTED]  
**Subject:** FW: Drawing - Land Adjacent Amarant House, Harewood End.

This message originated from outside of Herefordshire Council or Hoople. Please do not click links or open attachments unless you recognise the sender and know the content is safe.

I have conferred with my drainage consultant who has marked the positions of the test holes as requested (see below).

My consultant also confirms that the proposed drainage field is designed to fully conform with BS6297.


I trust that this responds to Points 3 and 4 you have raised.

Yours sincerely,

Paul Smith MRTPI

**From:** Tim Fycun [REDACTED]  
**Sent:** 02 August 2021 15:00  
**To:** Paul Smith <[paulsmithplanning@outlook.com](mailto:paulsmithplanning@outlook.com)>  
**Subject:** Drawing

Approx. Locations marked as requested  
All the best  
Tim



OS MasterMap 1250/2500/10000 scale  
Wednesday, August 7, 2019, ID: HMC-00819748  
[www.themapcentre.com](http://www.themapcentre.com)