

Corres – HBO – agent 10.6.2014

From: David Macrae [<mailto:architect.macrae@btinternet.com>]
Sent: 10 June 2014 17:36
To: Lowe, Sarah
Cc: Atkins, Charlotte; architect.macrae@btinternet.com
Subject: Re: Sollers Hope Court

Dear Sarah

Thank you for your email.

I spoke to Mr Perlman and his craftsman Roger today. All the panels are removed and the extent of the decay is much more than we saw on our visit.

Roger has marked up a photograph with all his proposed repairs which he or Mr Perlman will forward to you directly.

I spoke to the cork board supplier today and we agreed that the cork board would be substituted for the Kingspan as shown on the revised drg, but to retain the lime render and lime plaster on render mesh rather than use his thin coat render directly on the cork board.

Regards

David Macrae

Sent from my iPad

On 10 Jun 2014, at 17:03, "Lowe, Sarah" <sllowe@herefordshire.gov.uk> wrote:

Dear David

The extra details are acceptable, thank you. Are you going to send through the areas of timber repair/replacement as we discussed, so that I don't need to request a condition to be attached to the decision notice?

Kind regards

Sarah

Sarah L Lowe | Senior Building Conservation Officer

Herefordshire Council | Planning Services | PO Box 230 | Blueschool House | Blueschool Street | Hereford | HR1 2ZB
Direct Tel: 01432 261950 (NO VOICEMAIL FACILITY) | Mobile Tel: 07792 881685 | Email: sllowe@herefordshire.gov.uk