

Developer Services PO Box 3146 Cardiff CF30 0EH

Tel: +44 (0)800 917 2652 Fax: +44 (0)2920 740472

E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu Blwch Post 3146 Caerdydd CF30 0EH

Ffôn: +44 (0)800 917 2652 Ffacs: +44 (0)2920 740472

E.bost: developer.services@dwrcymru.com

Herefordshire Council PO Box 230 **Blueschool House Blueschool Street** Hereford HR1 2ZB

> Date: 17/01/2018 Our Ref: PLA0031950 Your Ref: 174698

Dear Sir,

Grid Ref: SO6260550367 362605 250367

Site: Land adjacent to Newlands, Stoke Lacy, Hereford

Development: Reserved matters application for 28 dwellings and access (outline approval P151937/O)

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We have no objection to the application for approval of the reserved matters subject to compliance with the requirements of the drainage conditions imposed on the outline planning permission, and the subsequent applications to vary the conditions thereon.

We reiterate that the public sewers in the vicinity of the development are designated to receive foul water only and therefore we would not consider the communication of surface water to the mains sewer.

Advisory Notes

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011.



Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn

Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Matthew Lord
Development Control Officer
Developer Services

