

Developer Services PO Box 3146 Cardiff CF30 0EH

Tel: +44 (0)800 917 2652 Fax: +44 (0)2920 740472

E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu Blwch Post 3146 Caerdydd CF30 0EH

Ffôn: +44 (0)800 917 2652 Ffacs: +44 (0)2920 740472

E.bost: developer.services@dwrcymru.com

Herefordshire Council PO Box 230 **Blueschool House Blueschool Street** Hereford HR1 2ZB

> Date: 18/09/2019 Our Ref: PLA0044633 Your Ref: 193042

Dear Sir/Madam

Grid Ref: SO5026637520 350266 237520

Site: Land north and south of Grafton Lane, Land north and south of Grafton Lane Hereford Development: Outline application for residential development (with all matters reserved except for access), footway/cycleway and vehicle turning head

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We have had the opportunity to assess this development as the applicant engaged with us through a pre planning enquiry and at that time we concluded that the immediate water supply network did not have the required capacity to service the site and recommended a hydraulic modelling assessment be undertaken to identify a point of connection and to understand if any reinforcement works are required.

To date we have not received any instruction to commence with this hydraulic assessment and we recommend that the applicant contacts us to discuss.

In the absence of such an assessment on the potable water we are only able to provide a connection point to a point of adequacy circa 1000m away from the site boundary at grid ref 350680, 238680.

With regards to foul drainage we have reviewed the information submitted as part of this application with particular focus on the Flood Risk Assessment ref 173077. The report captures discussions held to date and we can confirm that adequate capacity exists in the public sewer network to accommodate 300 residential dwellings. We note that the intention is to drain surface water to the Withy Brook and offer no further comment on this aspect of the proposal.

It is noted that an off site connection point has been identified, however the on site drainage network is only indicative.



Nelson, Treharris, Mid Glamorgan CF46 6LY

Gymraeg neu yn Saesneg

Notwithstanding the above, if you are minded to grant planning permission we request that the following Conditions and Advisory Notes are included within any subsequent consent.

Conditions

No development shall take place until a potable water scheme to serve the site has been submitted to and approved in writing by the Local Planning Authority. The scheme shall demonstrate that the existing water supply network can suitably accommodate the proposed development site. If necessary a scheme to upgrade the existing public water supply network in order to accommodate the site shall be delivered prior to the occupation of any building. Thereafter, the agreed scheme shall be constructed in full and remain in perpetuity.

Reason: To ensure the site is served by a suitable potable water supply.

No development shall commence until a drainage scheme for the site has been submitted to and approved in writing by the Local Planning Authority. The scheme shall provide for the disposal of foul, surface and land water, and include an assessment of the potential to dispose of surface and land water by sustainable means. Thereafter the scheme shall be implemented in accordance with the approved details prior to the occupation of the development and no further foul water, surface water and land drainage shall be allowed to connect directly or indirectly with the public sewerage system.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.



Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Matthew Lord
Development Control Officer
Developer Services

