

Herefordshire Council  
PO Box 230  
Blueschool House  
Blueschool Street  
Hereford  
HR1 2ZB

**Date: 18/12/2015**  
**Our Ref: PLA0016078**  
**Your Ref: 153404**

Dear Sir,

**Grid Ref: SO4494461365 344944 261365**

**Site: St. Mary's Farm, Kingsland**

**Development: Proposed demolition of existing farm buildings and the residential development of St. Mary's Farm with 16 dwellings (13 new units and 3 to be provided by conversion of barns)**

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We would request that if you are minded to grant Planning Consent for the above development that the **Conditions and Advisory Notes** provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

## **SEWERAGE**

### **Conditions**

No development shall commence until a drainage scheme for the site has been submitted to and approved in writing by the local planning authority. The scheme shall provide for the disposal of foul, surface and land water, and include an assessment of the potential to dispose of surface and land water by sustainable means. Thereafter the scheme shall be implemented in accordance with the approved details prior to the occupation of the development and no further foul water, surface water and land drainage shall be allowed to connect directly or indirectly with the public sewerage system.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

## **Advisory Notes**

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water Industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of [www.dwrcymru.com](http://www.dwrcymru.com)

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water on 0800 085 3968 to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

## **SEWAGE TREATMENT**

No problems are envisaged with the Waste Water Treatment Works for the treatment of domestic discharges from this site.

## **WATER SUPPLY**

No problems are envisaged with the provision of water supply for this development.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dwr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at [developer.services@dwrcymru.com](mailto:developer.services@dwrcymru.com)

Please quote our reference number in all communications and correspondence.

Yours faithfully,

**Matthew Lord**  
**Development Control Officer**  
**Developer Services**



Welsh Water is owned by Glas Cymru – a ‘not-for-profit’ company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni ‘nid-er-elw’.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.